


G2-3520WV Silhouette Handrail

Suggested Specifications



- 7-7/8" (200mm) height x 1-1/2" (38mm) round gripping diameter, extends 3-1/4" (82mm) from the wall
- G2-3520WV - Wood handrail available in red oak, maple or FSC® Certified Ash with and integrated non-PVC wall guard, with black reveals for returns and corners
- Non-PVC cover is manufactured with G2 BioBlend®, Inpro's exclusive blend of PETG and biopolymer;
- Lower wall guard is mounted on a sturdy .080" (2mm) thick, continuous aluminum retainer
- Meets ADA and ANSI criteria
- Manufactured in 8' - 16' (2.44m - 4.88m) standard lengths
- All mounting fasteners are included with each order



IPC.2219/REV.1

Inprocorp.com • 800.222.5556 • 262.679.9010
 World Headquarters S80 W18766 Apollo Drive, Muskego, WI 53150 USA

IPC •
 DOOR + WALL PROTECTION SYSTEMS
 A DIVISION OF INPRO®

G2-3520WV Silhouette Handrail

Suggested Specifications

PART 1 – GENERAL

1.01 SUMMARY

A. Non PVC Handrail systems for pedestrian safety and wall protection

1.02 SECTION INCLUDES

A. G2-3520WV Silhouette Handrail System, round wood handrail with integrated wall guard

1.03 REFERENCES

- A. American National Standards Institute (ANSI)
- B. American Society for Testing and Materials (ASTM)
- C. Americans with Disabilities Act (ADA)
- D. National Fire Protection Association (NFPA)
- E. Kitchen Cabinets Manufacturers Association (KCMA)
- F. National Emission Standards for Hazardous Air Pollutants (NESHAP)
- G. Society of Automotive Engineers (SAE)

1.04 SYSTEM DESCRIPTION

A. Performance Requirements: Provide handrail systems that conform to the following requirements of regulatory agencies and the quality control of IPC Door and Wall Protection Systems, InPro Corporation.

1. Fire Performance Characteristics: Provide handrail conforming with the NFPA Class A fire rating. Surface burning characteristics, as determined by ASTM E-84, shall be flame spread of 25 or less and smoke development of 450 or less.
2. Impact Strength: Provide materials that have been tested in accordance with the applicable provisions of ASTM D-256, Impact Resistance of Plastics.
3. Chemical and Stain Resistance: Provide material that shows resistance to stain when tested in accordance with applicable provisions of ASTM D-543.
4. Fungal and Bacterial Resistance: Provide material that does not support fungal or bacterial growth as tested in accordance with ASTM G-21 and ASTM G-22.
5. GREENGUARD Certified: Provide GREENGUARD Certified profiles. Profiles shall meet the requirements of GREENGUARD Certification Standards for Low-Emitting Products and GREENGUARD Product Emission Standard for Children & Schools.
6. Color Consistency: Provide components matched in accordance with SAE J-1545 - (Delta E) with a color difference no greater than 1.0 units using CIE Lab, CIE CMC, CIE LCh, Hunter Lab or similar color space scale systems.
7. Cold, heat and chemical resistance: Provide handrail system with wood components that have a finish that complies with the applicable provisions of ANSI/KCMA A161.1- 1990 for cold check, heat and chemical resistance.
8. Environmental compliance: Provide handrail system with wood components that have a finish that does not off gas or emit any VOC, after a full cure, as tested in accordance to the EPA, NESHAP, Method 24, 40CFR, Volume 60, Appendix A.
9. Code Compliance: Provide handrails that comply with all current ANSI and ADA requirements.

1.05 SUBMITTALS

- A. Product Data: Manufacturer's printed product data for each product indicated in this section.
- B. Detail Drawings: Mounting details with the appropriate fasteners for specific project substrates.
- C. Samples: Verification samples of handrail, 8" (203mm) long, in full size profiles of each type and color indicated.

D. Manufacturer's Installation Instructions: Printed installation instructions for each handrail.

1.06 DELIVERY, STORAGE AND HANDLING

- A. Deliver materials in unopened factory packaging to the jobsite
- B. Inspect materials at delivery to assure that specified products have been received.
- C. Store in original packaging in a climate controlled location away from direct sunlight.

1.07 PROJECT CONDITIONS

A. Environmental Requirements: Install products in an interior climate controlled environment.

1.08 WARRANTY

A. Standard IPC Limited Lifetime Warranty against material and manufacturing defects.

PART 2 – PRODUCTS

2.01 MANUFACTURER

- A. Acceptable Manufacturer: IPC Interior Protection Products and Decorative Surfaces, InPro Corporation, PO Box 406, Muskego, WI 53150, USA; Telephone: 800.222.5556, Fax: 888.715.8407, www.inprocorp.com
- B. Substitutions: Not permitted
- C. Provide all handrails and wall protection from a single manufacturer.

2.03 MANUFACTURED UNITS

- A. Handrail
 1. G2-3520WV Silhouette Handrail, 7-7/8" (200mm) height x 1-1/2" (38mm) round gripping diameter, system extends 3-1/4" (83mm) from the wall. System includes 1-1/2" (38mm) diameter wood top rail and an integrated 5" (127mm) cover/aluminum retainer wall guard.
 - a. Stainless steel handrail returns and corners, standard; Wood handrail. returns and corners, optional.

2.04 MATERIALS

- A. PETG
 1. Reformulated PETG with Biopolymer Blend: Snap-on covers of .080" (2mm) thickness shall be extruded from chemical and stain resistant PETG.
- B. Aluminum
 1. Continuous aluminum retainer of .080" (2mm) thickness shall be fabricated from 6063-T5 aluminum with a mill finish.
- C. Wood
 1. Wood shall be FAS grade, kiln dried, solid maple or red oak with moisture content of 5-9%.
 2. Forest Stewardship Council® Certified Wood: Shall be kiln dried solid FSC® Certified Ash.
- D. Stainless Steel
 1. Stainless Steel Bracket Extensions shall be made of type 201 stainless steel.

2.05 COMPONENTS

- A. Handrail returns and corners shall be fabricated of wood in a finish/color to match the wall guard.
- B. Molded wall guard returns, corners and brackets shall be made of injection molded thermoplastic.
- C. Molded reveals shall have a smooth finish and shall be black.
- D. Stainless steel bracket shall be fabricated from cast

stainless steel with a brushed finish or a solid color powder coat metal tone finish.

E. Fasteners: All mounting systems accessories appropriate for substrates indicated on the drawings shall be provided.

2.06 FINISHES

- A. Wood Stain: Color of the handrail to be selected, by the architect, from the IPC stain selection.
- B. Covers: Color of the wall guard cover to be selected, by the architect, from the IPC finish selection. Surface shall have a pebblette texture.
- C. Wood Finish: Handrail shall be finished with low- VOC water based UV finish.
- D. Stainless Steel Brackets
 1. Color of the stainless steel bracket to be selected by the architect from the solid color metal tone color palette.
 2. Color of stainless steel brackets shall be #4 satin finish stainless steel.
- E. Molded Components
 1. Molded wall guard returns and corners shall be of a color matching the wall guard. Surface shall have a pebblette texture.
 - F. Molded bracket components shall be a color matching the wall guard. Surface shall have a pebblette texture.

PART 3 – EXECUTION

3.01 EXAMINATION

- A. Examine areas and conditions in which the handrail system will be installed.
 1. Complete all finishing operations, including painting, before beginning installation of handrail system materials.
 2. Wall surface shall be dry and free from dirt, grease and loose paint.

3.02 PREPARATION

A. General: Prior to installation, clean substrate to remove dust, debris and loose particles.

3.03 INSTALLATION

A. General: Locate handrail as indicated on approved detail drawings for the appropriate substrate and in compliance with the IPC installation instructions. Install handrail level and plumb at the height indicated on the drawings.

3.04 CLEANING

A. At completion of the installation, clean surfaces in accordance with the IPC clean-up and maintenance instructions.

End of Section

Inprocorp.com • 800.222.5556 • 262.679.9010

World Headquarters S80 W18766 Apollo Drive, Muskego, WI 53150 USA

IPC®

DOOR + WALL PROTECTION SYSTEMS
A DIVISION OF INPRO®